

Some or all of these definitions may be found in this report:

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Below Detection Levels (BDL) - laboratory analysis indicates that the contaminant is not present.

Not Applicable (N/A) - does not apply.

Parts per million (ppm) - or milligrams per liter, (mg/l). One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) - or micrograms per liter, (µg/L). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Million Fibers per Liter (MFL) - a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

Variations & Exemptions (V&E) - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

Spanish (Español) Este informe contiene información muy importante sobre la calidad de su agua beber.

Tradúzcalo o hable con alguien que lo entienda bien.

To request a paper copy call (270) 395-7138.



Calvert City Water System 2019 Water Quality Report



Water System ID: KY0790056

Manager: Roger Colburn

270-395-7138

CCR Contact: Roger Colburn

270-395-7138

Mailing address:

P.O. Box 36

Calvert City, KY 42029

Meeting location and time:

City Hall – 861 East 5th Ave.

Calvert City, KY

2nd Tuesday each month at 4:00 PM

This report is designed to inform the public about the quality of water and services provided on a daily basis. Our commitment is to provide a safe, clean, and reliable supply of drinking water. We want to assure that we will continue to monitor, improve, and protect the water system and deliver a high quality product.

The source of water used by the Calvert City Municipal Water System is groundwater obtained from three wells located east of the corporate limits of Calvert City. The aquifer is comprised of Quaternary Period continental deposits and alluvial sands and gravels. The Calvert City Water System has implemented a Wellhead Protection Plan (WHPP). A susceptibility analysis included in the plan characterizes the risk for potential contamination of the aquifer as a medium risk. Potential contamination sources include spills of hazardous materials along the adjacent railroad and highways, leaking fuel storage tanks, agriculture activities and on-site wastewater treatment systems. The plan provides procedures for emergency response and notification should a release or spill of hazardous materials occur within the approved wellhead protection area. Calvert Water will continue working with the Kentucky Dept. of Environmental Protection to verify that businesses and industries located in the wellhead protection area implement best management practices to reduce the potential for a release of hazardous materials to the environment. A copy of the WHPP is on file for public review at City Hall.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater

runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Information About Lead:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local public water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.



To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old. **Copies of this report are available upon request by contacting our office during business hours.**

Regulated Contaminant Test Results Calvert City Municipal Water System

Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination
Alpha emitters [4000] (pCi/L)	15	0	3.49	3.49 to 3.49	Oct-17	No	Erosion of natural deposits
Barium [1010] (ppm)	2	2	0.023	0.023 to 0.023	Feb-17	No	Drilling wastes; metal refineries; erosion of natural deposits
Chromium [1020] (ppb)	100	100	0.7	0.7 to 0.7	Feb-17	No	Discharge from steel and pulp mills; erosion of natural deposits
Fluoride [1025] (ppm)	4	4	0.40	0.4 to 0.4	Feb-17	No	Water additive which promotes strong teeth
Nitrate [1040] (ppm)	10	10	0.656	0.656 to 0.656	Nov-19	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits
Chlorine (ppm)	MRDL = 4	MRDLG = 4	0.99 (highest average)	0.099 to 1.3	2019	No	Water additive used to control microbes.
TTHM (ppb) (Stage 2) [total trihalomethanes] (Annual Sample)	80	N/A	5 (high site)	4 to 5 (range of individual sites)	2019	No	Byproduct of drinking water disinfection.

Household Plumbing Contaminants

Copper [1022] (ppm) sites exceeding action level 0	AL = 1.3	1.3	0.137 (90 th percentile)	0.0118 to 0.163	Jul-19	No	Corrosion of household plumbing systems
Lead [1030] (ppb) sites exceeding action level 0	AL = 15	0	2 (90 th percentile)	0 to 4	Jul-19	No	Corrosion of household plumbing systems

	Average	Range of Detection
Fluoride (added for dental health)	0.8	0.7 to 0.97
Sodium (EPA guidance level = 20 mg/L)	9.1	9.07 to 9.07

Secondary contaminants do not have a direct impact on the health of consumers. They are being included to provide additional information about the quality of the water.

Secondary Contaminant	Maximum Allowable Level	Report Level	Range of Detection	Date of Sample
Chloride	250 mg/l	10.1	10.1 to 10.1	Mar-19
Copper	1.0 mg/l	0.0519	0.0519 to 0.0519	Mar-19
Corrosivity	Noncorrosive	-0.319	-0.319 to -0.319	Mar-19
Fluoride	2.0 mg/l	0.6	0.6 to 0.6	Mar-19
pH	6.5 to 8.5	7.3	7.3 to 7.3	Mar-19
Sulfate	250 mg/l	23.3	23.3 to 23.3	Mar-19
Total Dissolved Solids	500 mg/l	278	278 to 278	Mar-19
Zinc	5 mg/l	0.03	0.03 to 0.03	Mar-19

